



PAVUS, a.s.

AUTHORIZED BODY 216
NOTIFIED BODY 1391
ACCREDITED CERTIFICATION BODY FOR
PRODUCTS N° 3041

Branch: FIRE TESTING LABORATORY
VESELÍ NAD LUŽNICÍ
Čtvrť J. Hybeše 879
CZ 391 81 Veselí nad Lužnicí
Czech Republic

Address:
Prosecká 412/74, 190 00 Praha 9 – Prosek
Tel.: 286 019 587 Fax: 286 019 590
E-mail: mail@pavus.cz, http://www.pavus.cz

Phone: +420 381 477 418
Fax: +420 381 477 419
Mail to: veseli@pavus.cz

REACTION TO FIRE CLASSIFICATION REPORT

The object of classification: *Construction products excluding floorings and linear pipe thermal insulation products in accordance with CSN EN 13501-1, clause 11*

Issue number:

PK1-01-17-069-E-0

Product name and type: *Textile PTX Artist Mambo 564160 237*

Sponsor: *PONGS TECHNICAL TEXTILES GmbH
Bahnhofstrasse 21
DE 07919 Mühltruff
Germany*

Issuing organization: *PAVUS, a.s.
Authorized Body 216
Notified Body 1391
Accredited certification body for products No 3041
- Accreditation issued by Czech Accreditation Institute, Public Service Company
- Certificate of Accreditation N° 353/2016
Prosecká 412/74
190 00 PRAHA 9
Order no. Z21070341*

Date of issue: 2017-10-12

Copies in total: 4

Copy number: 1

Pages in total: 4

1 INTRODUCTION

- 1.1 This Classification Report specifies classification method for the product *PTX Artist Mambo 564160 237* in conformity with the procedures set forth in CSN EN 13501-1+A1:2010.
- 1.2 This Classification Report has 4 pages and it can be used or reproduced as a whole only.

2 DETAILED INFORMATION ON THE ELEMENT TO BE CLASSIFIED

2.1 General

The product – *PTX Artist Mambo 564160 237* is made by the company PONGS TECHNICAL TEXTILES GmbH, Bahnhofstrasse 21, DE 07919 Mühltruff, Germany. It is used free-hanging as substrate for digital print, displays etc.

2.2 Product description

Thickness: 0.25 mm
Mass per unit area: 0.17 kg/m²
Colour: white
Composition: 100 % PES woven fabric, INK-JET-PU-Coating

3 REPORTS AND RESULTS IN SUPPORT OF CLASSIFICATION

3.1 Reports

Name of the Laboratory Address Accreditation number:	Name of sponsor of the Test Report	Report number Date of issue	Test method
<i>PAVUS, a. s. Veseli nad Luznici ATL No. 1026</i>	<i>PONGS TECHNICAL TEXTILES GmbH Bahnhofstrasse 21 DE 07919 Mühltruff Germany</i>	<i>Pr-17-1.209 2017-10-12</i>	<i>ČSN EN 13823+A1:2015</i>
		<i>Pr-17-1.210 2017-10-12</i>	<i>ČSN EN ISO 11925-2:2011</i>

3.2 Results

Test method	Parameter	Number of tests	Results	
			Continuous parameter-mean	Compliance with parameters
CSN EN 13823	FIGRA _{0.2 MJ} (W/s)	3	0.0	≤ 120 (B)
	THR _{600s} (MJ)		0.3	≤ 7.5 (B)
	LFS < edge of specimen		-	yes (B)
	SMOGRA (m ² /s ²)		0.0	≤ 30 (s1)
	TSP _{600s} (m ²)		25.7	≤ 50 (s1)
	non-occurring of flaming droplets/particles		-	yes (d0)
CSN EN ISO 11925 - 2	F _s ≤ 150 mm up to 60 s	6	30	yes (B)
Surface exposure	Filter paper non-ignition	6	-	yes (d0)
CSN EN ISO 11925 - 2	F _s ≤ 150 mm up to 60 s	6	60	yes (B)
Edge exposure	Filter paper non-ignition	6	no	yes (d2)

4 CLASSIFICATION AND FIELD OF APPLICATION

4.1 Classification references

This classification was carried out in conformity with CSN EN 13501-1+A1:2010.

4.2 Classification

The product - *PTX Artist Mambo 564160 237*- in conformity with its behaviour under the reaction-to-fire tests, is classified as follows:

Reaction to fire class: B-s1,d2

4.3 The field of application

This classification applies for the following parameters of the product:

Thickness: 0.25 mm
 Mass per unit area: 0.17 kg/m²
 Colour: white
 Composition: 100 % PES woven fabric, INK-JET-PU-Coating

This classification applies for the following end-use applications:

Free placed product.

5 RESTRICTIONS

This Classification Report does substitute neither the type approval nor the product certificate.

This classification is valid, unless the conditions, under which it was issued, have been changed. The sponsor may request the issuing authority to review the influence of changes to the classification validity.

Therefore the Testing Laboratory has no part in preparing the product specimens for tests although the Laboratory provides, on manufacturer's request, a suitable certification that the Laboratory took part in monitoring the preparation of specimens for tests.

Elaborated by:



.....
Ing. Pavla HEJNÁ

Fire testing laboratory

Approved by:



.....
Ing. Jaroslav DUFEK

PAVUS, a. s.
Autorizovaná osoba AO 215
Pobočka
391 81 Veselí nad Lužnicí

